



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(An ISO : 9001 : 2015, ISO 14001:2015 & ISO 45001:2018 & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPCCB & HSPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Test Report of	Report Code	Date of Issue
Ambient Noise	N-281220-01	02/01/2021

Issued To: **M/S Lalitpur Power Generation Company Limited**
Village- Mirchwara and Burogaon, Tehsil- Mahroni, Lalitpur-284123 (U.P)
India

SAMPLING & ANALYSIS DATA

Sample Drawn On : 26/12/2020
 Sample Drawn By : Mr. Amit Sharma (NTL)
 Sample Received On : 28/12/2021
 Sample description : Ambient Noise
 Sampling Location : Near-CCR Building
 Analysis Duration : 28/12/2020 to 02/01/2021

1	2	3	4	5	6	7	8	9	10
59.3	57.6	58.0	58.9	57.9	58.2	60.1	58.6	59.1	58.3
Test Parameters		Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq					
Maximum Sound Level		60.1	dB(A)	Category of Area/ Zone	Day Time	As per Factories Act-1948 for Work zone Noise			
Minimum Sound Level		57.9	dB(A)	Industrial Area	75	90			
Average Value		58.6	dB(A)	Residential Area	55				
				Commercial Area	65				
				Silence Zone	50				

Notes:

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. Responsibility of the Laboratory is limited to the invoiced amount only.
3. This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
4. This test report will not be used for any publicity/legal purpose.
5. The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.

CHECKED BY

AUTHORIZED SIGNATORY

Laboratory : GT-20, Sector-117, Noida, Gautam Budh Nagar - 201301

E. : noida.laboratory@gmail.com, info@noidalabs.com W.: www.noidalabs.com



Analyzing for an Assured Future

NOIDA TESTING LABORATORIES

(An ISO : 9001 : 2015, ISO 14001:2015 & ISO 45001:2018 & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB & HSPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Test Report of	Report Code	Date of Issue
Ambient Noise	N-281220-02	02/01/2021

Issued To: **M/S Lalitpur Power Generation Company Limited**
Village- Mirchwara and Burogaon, Tehsil- Mahroni, Lalitpur-284123 (U.P)
India

SAMPLING & ANALYSIS DATA

Sample Drawn On : 26/12/2020
 Sample Drawn By : Mr.Amit Sharma (NTL)
 Sample Received On : 28/12/2020
 Sample description : Ambient Noise
 Sampling Location : Near-T.G Inside sample done at 1.7 meter
 Distance from T.G
 Analysis Duration : 28/12/2020 to 02/01/2021

1	2	3	4	5	6	7	8	9	10
82.3	83.3	84.5	84.6	86.3	84.5	84.5	83.9	83.9	83.8

Test Parameters	Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq		
			Category of Area/ Zone	Day Time	As per Factories Act-1948 for Work zone Noise
Maximum Sound Level	86.3	dB(A)	Industrial Area	75	90
Minimum Sound Level	82.3	dB(A)		Residential Area	
Average Value	84.2	dB(A)	Commercial Area	65	
			Silence Zone	50	

Notes:

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. Responsibility of the Laboratory is limited to the invoiced amount only.
3. This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
4. This test report will not be used for any publicity/legal purpose.
5. The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.

CHECKED BY

AUTHORIZED SIGNATORY



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(An ISO : 9001 : 2015, ISO 14001:2015 & ISO 45001:2018 & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB & HSPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Test Report of	Report Code	Date of Issue
Ambient Noise	N-281220-03	02/01/2021

Issued To: **M/S Lalitpur Power Generation Company Limited**
Village- Mirchwara and Burogaon, Tehsil- Mahroni, Lalitpur-284123 (U.P)
India

SAMPLING & ANALYSIS DATA

Sample Drawn On : 26/12/2020
Sample Drawn By : Mr. Amit Sharma (NTL)
Sample Received On : 28/12/2020
Sample description : Ambient Noise
Sampling Location : T.G, outside Area
Analysis Duration : 28/12/2020 to 02/01/2021

1	2	3	4	5	6	7	8	9	10
68.8	69.1	69.1	68.4	68.9	68.6	68.8	68.5	68.9	68.8
Test Parameters		Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq					
Maximum Sound Level		69.1	dB(A)	Category of Area/ Zone	Day Time	As per Factories Act-1948 for Work zone Noise			
Minimum Sound Level		68.4	dB(A)	Industrial Area	75	90			
Average Value		68.8	dB(A)	Residential Area	55				
				Commercial Area	65				
				Silence Zone	50				

Notes:

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. Responsibility of the Laboratory is limited to the invoiced amount only.
3. This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
4. This test report will not be used for any publicity/legal purpose.
5. The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.

CHECKED BY

AUTHORIZED SIGNATORY



Laboratory : GT-20, Sector-117, Noida, Gautam Budh Nagar - 201301

E. : noida.laboratory@gmail.com, info@noidalabs.com W.: www.noidalabs.com



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(An ISO : 9001 : 2015, ISO 14001:2015 & ISO 45001:2018 & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB & HSPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Test Report of	Report Code	Date of Issue
Ambient Noise	N-281220-04	02/01/2021

Issued To: **M/S Lalitpur Power Generation Company Limited**
Village- Mirchwara and Burogaon, Tehsil- Mahroni, Lalitpur-284123 (U.P)
India

SAMPLING & ANALYSIS DATA

Sample Drawn On : 26/12/2020
Sample Drawn By : Mr. Amit Sharma (NTL)
Sample Received On : 28/12/2020
Sample description : Ambient Noise
Sampling Location : Walkway between Boiler & ESP
Analysis Duration : 26/12/2020 to 02/01/2021

1	2	3	4	5	6	7	8	9	10
63.5	63.9	63.0	63.4	63.5	63.0	64.3	63.2	65.2	62.9
Test Parameters		Results	Units	Requirement (as per CPCB Guidelines Limits in dB (A) Leq					
Maximum Sound Level		65.2	dB(A)	Category of Area/ Zone		Day Time	As per Factories Act- 1948 for Work zone Noise		
Minimum Sound Level		62.9	dB(A)	Industrial Area		75	90		
Average Value		63.6	dB(A)	Residential Area		55			
				Commercial Area		65			
				Silence Zone		50			

Notes:

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. Responsibility of the Laboratory is limited to the invoiced amount only.
3. This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
4. This test report will not be used for any publicity/legal purpose.
5. The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.

CHECKED BY

AUTHORIZED SIGNATORY





Analyzing for an Assured Future

NOIDA TESTING LABORATORIES

(An ISO : 9001 : 2015, ISO 14001:2015 & ISO 45001:2018 & NABL Accredited Laboratory)
MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB & HSPCB Recognized Laboratory

+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Test Report of	Report Code	Date of Issue
Ambient Noise	N-281220-05	02/01/2021

Issued To: **M/S Lalitpur Power Generation Company Limited**
Village- Mirchwara and Burogaon, Tehsil- Mahroni, Lalitpur-284123 (U.P)
India

SAMPLING & ANALYSIS DATA

Sample Drawn On : 26/12/2020
Sample Drawn By : Mr. Amit Sharma (NTL)
Sample Received On : 28/12/2020
Sample description : Ambient Noise
Sampling Location : Near-Admin Building
Analysis Duration : 26/12/2020 to 02/01/2021

1	2	3	4	5	6	7	8	9	10
56.9	56.4	57.7	58.0	58.1	58.4	58.6	58.9	59.1	59.0
<u>Test Parameters</u>		<u>Results</u>	<u>Units</u>	<u>Requirement (as per CPCB Guidelines Limits in dB (A) Leq</u>					
<u>Maximum Sound Level</u>		59.1	dB(A)	<u>Category of Area/ Zone</u>	<u>Day Time</u>	<u>As per Factories Act-1948 for Work zone Noise</u>			
<u>Minimum Sound Level</u>		56.4	dB(A)	Industrial Area	75	90			
<u>Average Value</u>		58.1	dB(A)	Residential Area	55				
				Commercial Area	65				
				Silence Zone	50				

Notes:

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. Responsibility of the Laboratory is limited to the invoiced amount only.
3. This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
4. This test report will not be used for any publicity/legal purpose.
5. The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.

CHECKED BY

AUTHORIZED SIGNATORY



Laboratory : GT-20, Sector-117, Noida, Gautam Budh Nagar - 201301

E. : noida.laboratory@gmail.com, info@noidalabs.com W.: www.noidalabs.com